

FOREWORD

We welcome you to the 2nd International Conference on Science and Technology for Sustainability (IcoSTechS) held in Pekanbaru, Indonesia, 30th November - 1st December 2016. It is with deep satisfaction that I write this Foreword to the Proceedings of IcoSTechS.

IcoSTechS continues a tradition of bringing together researchers, academics and professionals from all over the world, experts in science and Technology.

The main objective of the conference is to provide the opportunities for collaboration and reflection that have the potential to greatly enhance the infrastructure and capacity for conducting and applying science and technology for sustainability. The IcoSTechS is expected to bridge the gap between academia, business, industries, and governments by creating awareness of current development in sustainable technologies.

Thank you for all authors and participants for your contributions. Your contributions helped to make the Conference as outstanding as it has been. The papers contributed the most recent scientific knowledge known in the field of Information Technology, Industrial Engineering, Electrical Engineering and Mathematics Sciences.

In addition, I would like to thank you for two keynote speaker **Prof. Yasutomi Kinoshita** from School of Medicine, Gifu University, Japan, and by **Prof. Dr. Ing. Ir. Kalamullah Ramli, M.Eng**, Director General of Post and ICT Operations of the Ministry of Communication and Information Technology (2013 – 2016), Indonesia.

These Proceedings will furnish the scientists of the world with an excellent reference book. I trust also that this will be an impetus to stimulate further study and research in all these areas. We are pleased to present the proceedings of the conference as its published record.

Dr. Harris Simaremare, MT
Conference Chair

REMARK

Assalamu'alaikum wr. wb.

Welcome to Pekanbaru,

It is my great pleasure and privilege to welcome all of you to 2nd International Conference on Science and Technology for Sustainability (IcoSTechS), which bring together key representatives from your expert research area. We are indeed pleased that so many eminent speakers in these field are present to lead the discussion.

It is our commitment to play roles together with international communities in education and research. In line with this commitment, we held the 2nd International Conference on Science and Technology for Sustainability (IcoSTechS) in Pekanbaru.

Please allow me to give my great appreciation to all of the committee members, International Honorary Board and all stockholders that helped to make this Conference as outstanding as it has been.

The last, please enjoy your time in Pekanbaru and see you in the next conference.

Wassalamu'alaikum wr. wb.

Dr. Hartono, M.Pd

Dean of faculty Science and Technology
UIN Sultan Syarif Kasim Riau
Indonesia

COMMITTEE

Honorary Executive Committee

- Prof. Dr. H. Munzir Hitami, MA. (Rector of State Islamic University of Sultan Syarif Kasim Riau)
- Prof. Dr. Syafris Akhlus, M.Sc (Chair of BKS PTN Wilayah Barat)
- Prof. Rose Alinda Alias (Vice Rector of Universiti Teknologi Malaysia)
- Prof. Dr. Nicholas Gascoin (Head of the Research Cooperation Office at France Embassy)
- Prof. Dr. Aini Hussain (National University of Malaysia, Malaysia)
- Prof. Dr. Thierry Mare (Universite de Rennes 1, Rennes, France)

International Advisory Board

- Dr. Hartono, M.Pd (Dean of Faculty of Science and Technology, UIN Suska Riau, Indonesia)
- Prof. Dr. Moh. Sholeh (Dean of Faculty of Science and Technology, UIN Sunan Ampel, Indonesia)
- Prof. Dr. Al Rasyidin (Dean of Faculty of Science and Technology, UIN Sumatera Utara, Indonesia)
- Dr. Agus Salim. M.Si (Dean of Faculty of Science and Technology, UIN Syarif Hidayatullah Jakarta, Indonesia)
- Dr. Maizer Said Nahdi, M.Si (Dean of Faculty of Science and Technology, UIN Sunan Kalijaga, Indonesia)
- Dr. H. Ruswan, M.A (Dean of Faculty of Science and Technology, UIN Walisongo Semarang, Indonesia)
- Dr. Mohamed El Amine Brahmia (École d'ingénieurs CESI, Strasbourg, France)
- Dr. Sofiane Hamrioui (University of Haute Alsace, France)
- Prof. Donggyu Sim (Kwangwoon University, South Korea)
- Prof. Dr. Sevia Mahdaliza Idrus (Universiti Teknologi Malaysia, Malaysia)
- Prof. Dr. Mustafa Mat Deris (Tun Hussein Onn University of Malaysia, Malaysia)
- Prof. Naomie Salim (Universiti Teknologi Malaysia, Malaysia)
- Jehan Zeb Shah, Ph.D (Pakistan)
- Dr. Solomon Zakwoi (Assistant Director of Satellite Bus, Ministry of Research, Nigeria)
- Dr. Zaid Ahmad Shamsan (Al-Imam Muhammad ibn Saud University, Kingdom of Saudi Arabia)
- Prof. Dr. Ing. Magnus Jaeger (Ostbayerische Technische Hochschule Amberg-Weiden, Germany)
- Dr. Hashimu Uledi Iddi (Department of Electronic and telcom engineering University of Dar es Salaam, Tanzania)
- Dr. Khaled Chetehouna (INSA Centre Val de Loire, France)

Conference Chair

- Dr. Haris Simaremare (Faculty of Science and Technology, UIN Sultan Syarif Kasim Riau, Indonesia)

Technical Program Committee

- Dr. Okfalisa (UIN Sultan Syarif Kasim Riau, Indonesia)
- Assoc. Prof. Tole Sutikno, Ph.D (Institute of Advanced Engineering and Science)
- Dr. Imam MIS (Institute of Advanced Engineering and Science)
- Dr. Noritawati (Universiti Teknologi Mara, Malaysia)
- Assist. Prof. Dr. Ladda Suanmali (Suan Dusit University, Thailand)
- Assist. Prof. Dr. Mohammed Abdulatef Ali Al-Shargabi (Najran University, Kingdom of Saudi Arabia)
- Assist. Prof. Dr. Ahmed Hamza Osman Ahmed (University of Africa, Zimbabwe)
- Dr. Mohamed El Amine Brahmia (École d'ingénieurs CESI, Strasbourg, France)
- Dr. Alwis Nazir (UIN Sultan Syarif Kasim Riau, Indonesia)
- Dr. Alex Wenda (UIN Sultan Syarif Kasim Riau, Indonesia)
- Dr. Dedi Irawan (UIN Sultan Syarif Kasim Riau, Indonesia)
- Dr. Rika (UIN Sultan Syarif Kasim Riau, Indonesia)
- Dr. Fitra Lestari (UIN Sultan Syarif Kasim Riau, Indonesia)

International Program Committee

- Prof. Dr. Abdul Hakim Halim, M. Eng (Bandung Institute of Technology, Indonesia)
- Dr. Rosniwati (Universiti Sains Malaysia, Malaysia)
- Dr. Teddy Purnamirza (Vice Dean of Faculty of Science and Technology, UIN Sultan Syarif Kasim Riau, Indonesia)
- Dr. Rado Yendra (Vice Dean of Faculty of Science and Technology, UIN Sultan Syarif Kasim Riau, Indonesia)
- Dr. Ir. Cecep Hidayat, M.P (Vice Dean of Faculty of Science and Technology, UIN Sunan Gunung Djati, Indonesia)
- Dr. Abdul Halim Daulay, S.T., M.Si (Vice Dean of Faculty of Science and Technology, UIN Sumatera Utara, Indonesia)
- Dr. Ir. Elpawati, M.P (Vice Dean of Faculty of Science and Technology, UIN Syarif Hidayatullah, Indonesia)
- Dr. Wasilah, S.T., M.T (Vice Dean of Faculty of Science and Technology, UIN Alauddin, Indonesia)
- Dr. Khurul Wardati, M.Si (Vice Dean of Faculty of Science and Technology, UIN Sunan Kalijaga, Indonesia)
- Dr. Eni Purwati, M.Ag (Vice Dean of Faculty of Science and Technology, UIN Sunan Ampel, Indonesia)
- Dr. Lianah, M.Pd (Vice Dean of Faculty of Science and Technology, UIN Walisongo, Indonesia)
- Dr. Sri Harini (Vice Dean of Faculty of Science and Technology, UIN Maulana Malik Ibrahim, Indonesia)
- Dr. Riswan Efendi (UIN Sultan Syarif Kasim Riau, Indonesia)
- Dr. Ali Ahmed (Karary University , Sudan)
- Dr. Imran Ademola Adeleke (Principal Lecturer Adeniran Ogunsanya College of Education, Lagos, Nigeria)
- Dr. Murniati Mukhlisin (Essex University, United Kingdom)

ICOSTECHS 2016 SCHEDULE

Wed, November 30th, 2016

CONFERENCE DAY

- 07.30 – 09.10 Opening Ceremony**
Coffee Break
- 09.30 – 12.00 Session I Presentation from Keynote Speaker**
Prof. Yasutomi Kinosada
Moderator : Wresni angraini, ST., MM

Prof. Dr. Ing. Ir. Kalamullah Ramli, M.Eng.
Moderator : M. Jasman, S.Kom, M.InfoSys
- 13.30 – 16.00 Session II Parallel Presentation**
Moderator Room A : Idria maita, S.Kom., M.Sc
Moderator Room B : Saide, S.Kom, M.Kom, M.I.M
Coffee Break
- 21.00 – 21.15 Closing Ceremony**

PARALLEL SESSION SCHEDULE

Room A

NO	NAME	PAPER CODE	TIME
1	Rajesh Kumar	2	13.30 – 13.45
2	Fatihah Shafiqah	3	13.45 – 14.00
3	Eflita Yohana	19	14.00 – 14.15
4	M. Marizal	11	14.15 – 14.30
5	Muhammad Ihsan Zul	8	14.30 – 14.45
Break			14.45 – 15.00
6	Fitri Aryani	23	15.00 – 15.15
7	Indra Wijaya	15	15.15 – 15.30
8	Yahya Badrussalam	13	15.30 – 15.45
9	Mustakim	22	15.45 – 16.00

Room B

NO	NAME	PAPER CODE	TIME
1	Enwelum I Mbadiwe	6	13.30 – 13.45
2	Laili Iwani	4	13.45 – 14.00
3	Liliana	10	14.00 – 14.15
4	Maxrizal	20	14.15 – 14.30
5	Keumala Anggraini	14	14.30 – 14.45
Break			14.45 – 15.00
6	Riswan Efendi	7	15.00 – 15.15
7	lia anggraini	18	15.15 – 15.30
8	Rahmat Rizal Andhi	17	15.30 – 15.45
9	Riwinoto	5	15.45 – 16.00

CONTENTS

	PAGE
FOREWORD.....	i
REMARK.....	ii
COMMITTEE	iii
ICOSTECHS 2016 SCHEDULE	v
PARALLEL SESSION SCHEDULE.....	vi
CONTENT.....	vii
1 Rajesh Kumar, Erwan Sulaiman, Faisal Khan, Laili Iwani Jusoh, Fatimah Shafiqah Bahrim Influence of Rotor Pole Number on the Performance of Outer Rotor Permanent Magnet Flux Switching Machine for Downhole Application	1
2 F. S. Bahrim, E. Sulaiman, L. I. Jusoh, R. Kumar A novel combination notching and pole pairing method for cogging torque reduction in IPMSM and PMFSM.	6
3 L. I. Jusoh, E. Sulaiman, R. Kumar, F. Bahrim High Power Density of Permanent Magnet Flux Switching Machines For Electric Bicycle Application	12
4 Enwelum Mbadiwe Ignatius and Erwan Sulaiman Electromagnetic Performance of 12S-14P Outer Segmental Rotor Permanent Magnet Flux Switching Motor for Electric Scooter Drives	18
5 Riswan Efendi, Nureize Arbaiy, Mustafa Mat Deris Forecasting with Limited Data Using Fuzzy Random Auto-Regression Model	24
6 Muhammad Ihsan Zul Prediction of Student Final Grade by using k-Nearest Neighbor Algorithm	29
7 Liliana, Rahmad Analysis Reliability Distribution System Uses The Method of Reliability Index Assessment (RIA)	34
8 Muhammad Marizal, Ari Pani Desvina, Rado Yendra Forecasting Consumer Price Index of Indonesian Using Holt's Exponential Smoothing	39
9 Ariyani Muljo The Ethno-mathematical Study in Acehese Culture (The Traditional Dances Analysis from Tanah Rencong)	44
10 Keumala Anggraini, Lestari Handayani Arabic Character Recognition Using Learning Vector Quantization	53
11 Indra Wijaya, Rizky Ema Wulansari Android Mobile on Subject Information and Communication Technology (Case Study for Class X Senior High School -SMA)	58

12	Rahmat Rizal Andhi, Ary Setijadi Prihatmanto, Aciek Ida Wuryandari Virtual World Environment Design for Vidyanusa E-Learning System	64
13	Lia Anggraini, Muhammad Firdaus Yan, Suwanto Sanjaya, lis Afriyanty, Alwis Nazir Prediction of Divorce Case Ruling Using Naïve Bayes Classifier	71
14	Eflita Yohana, Bambang Yunianto, Setiawan Aditya N S, Didik Ari Wibowo, and Vita Paramita Evaporative Cooling Utilization for Electric Energy Savings on Split Air-Conditioner	77
15	Maxrizal, Baiq Desy Aniska Prayanti A New Method of Hill Cipher The Rectangular Matrix as The Private Key	81
16	Mustakim, Agus Buono, Irman Hermadi Modeling of Analytic Hierarchy Process and Simple Additive Weighting for Selection of Regional Development Renewable Energy Center	84
17	F.Aryani, C. M. Corazon Inverse of Tridiagonal Toeplitz Matrix By Adjoint Method	89
18	Riwinoto Usage of Educational 2D and 3D Animation (Case study: system of biopori)	97

Analysis Reliability Distribution System Uses The Method of Reliability Index Assessment (RIA)

Liliana

Departement of Electrical Engineering
Faculty of Sains and Technology, UIN Suska Riau
Pekanbaru, Indonesia

Rahmad

Departement of Electrical Engineering
Faculty of Sains and Technology, UIN Suska Riau
Pekanbaru, Indonesia

Abstract— Reliability can be seen the extent to which electric power can supply continuously in one year to consumers. This research aims to know the index of the reliability distribution system network 20 kV at PT PLN (Persero) Rayon Panam Pekanbaru Feeder 12 Kualu. The calculations and analysis use RIA (Reliability Index Assessment) method, the first analysis, system is assumed in perfect switching condition, and the second in imperfect switching. Based on calculation and analysis, the conditions in perfect switching, the value of SAIFI 0.30 times/year, SAIDI hour/year 1.19, CAIDI 6.63 hours/year. the conditions in imperfect switching, the value of SAIFI 0.63 times/year, SAIDI 4.19 hours/year, CAIDI 6.65 hours/year. Thus the distribution network feeder 12 Kualu still reliable. The value of SAIFI and SAIDI is smaller than specified by PLN. Based on standard PLN for the value are SAIFI 3.2 times/year and SAIDI 21 hours/year.

Keywords— *index of the realibility; distribution system, RIA method, perfect switching, imperfect switching*

I. INTRODUCTION

Demand of Electrical energy from year to year increasing in line with the growing needs of the economy and the welfare of society. The growing demand for electrical energy is balanced with the need to improve the power generation and the capabilities of infrasturcture, resulting in the distribution of electrical energy to consumers goes well with the quality of the distribution of electrical energy that meets the standards. In electric power distribution system, the level of reliability is the most important thing in determining the performance of the system. Reliability can be measured by the extent to which electric power system could supply energy to the load in one year. Disruption or damage of electric power distribution system will affect the value of the reliability of the distribution system [2].

To be able to determine the level of reliability of a system, it must be held by way of examination through a calculation as well as the analysis of the success rate of the performance or operation of the system. There are three basic parameters in reliability that can be used to evaluate the radial distribution systems i.e. number average failure (λ), the average extinguishing time (r), and the annual extinguishing time (U).

In the analysis of the reliability of the distribution network of 20 kV, to determine the level of possibly the author uses the

method of Reliability Index Assessmen (RIA) which is an approach to predict the failure of distribution system based on the topology of the system and the data concerning the reliability of the components. RIA method logs a failure that occurred on the equipment in a comprehensive manner, and then identify the failure so that the resulting reliability indexes that include the system Average Intrupcion frequency index (SAIFI), system Average Intrupcion Duration index (SAIDI), Customer Average Intrupcion Duration index (CAIDI) [2].

II. RELIABILTY OF RIA METHOD

A. Reliability of Distribution System

Electric power distribution system of functioning distributed electric power to the constumer through a network of low voltage, whereas a transimi channel serves to channel the extra high-voltage power ke load centers in the great power (via the distribution network) [7].

Reliability is the success rate of the performance of a system or part of the system, to be able to give better results in a period of time and in certain operating conditions, determine from a system, the examination should be held by way of calculations or analysis of the success rate of the performance or operation of the systems reviewed, in a certain period and then compare it to the previous standards established [4].

There are a few things to know before calculating system reliability index that is by knowing the value of equipment reliability data. These data were obtained from the SPLN 59 in 1985 for equipment reliability data [12]. As shown in TABLE 1. Index of reliability on radial SUTM SPLN 68-2 in 1986 where for SAIFI was 3.2 times/year and SAIDI of 21 hours/year [14].

TABLE 1. DATA RELIABILITY EQUIPMENT

Equipment	Failure Rate	Repair Time
Circuit Breaker	0,004 failure/unit/year	10
Overhead System	0,2 failure/km/year	3
Distribution Transformer	0,005 failure/unit/year	10
Recloser	0,005 failure/unit/year	0,25
Underground System	0,07 failure/km/year	

B. Method of Reliability Index Assessment (RIA)

RIA method is an approach used to predict the failure of

distribution system based on the topology of the system and the data concerning the reliability of the components. Functionally RIA log failures that occur on equipment in a comprehensive manner, and then identify the failure, and analyzing the failure mode. The philosophy of the RIA method is a system of modes that involve the analysis of bottom-up in which a specific failure mode analysis of sub system, seen its effect on the whole system so that it can be generated index of reliability that has contributed to the index of the reliability of the entire system. The data required in the RIA method is [5].

- Data feeder 20 kV distribution network system thoroughly with load points.
- the number of Data customers at any point of the load
- Parameters data system reliability




Fig.1. Input dan Output of RIA Method [4]

Stage of RIA Method is




Fig. 2. RIA Method

C. Value Reliability Factors

Factors that must be known and counted before doing the calculation and analysis of reliability are: MTTF, MTTR, failure rate, and downtime rate.

a. Mean Time To Failure (MTTF)

the average time the failure occurs during operation of a system [4]

$$MTTF = \frac{T1+T2+T3.....Tn}{n} \quad (1)$$

Where T is up time and n is the number of failure. From the data obtained then performed the calculation penyulang each for MTTF each year.

b. Mean Time To Repair (MTTR)

The average time it takes to do the repairs against the occurrence of the failure of a system

$$MTTR = \frac{L1+L2+L3.....+Ln}{N} \quad (2)$$

Where L is repair time and N is number of repair. From the results obtained could be seen whether damage or disturbances in the feeder could be handled quickly or not.

c. Rate of Failure (λ)

The frequency of a system or component failed to work

$$\lambda = \frac{1}{MTTF} \quad (3)$$

d. Downtime Rate (μ)

length frequency of a system/component in a time of repair (condition OFF)

$$\mu = \frac{1}{MTTR} \quad (4)$$

So the larger the value of μ then the sooner repair time also means getting good value the reliability of a system.

Calculation of system reliability index assumed to be on condition of imperfect switching. There are three steps that are used to get the value of SAIFI, SAIDI, and CAIDI [9]

a. System Average Interruption Frequency Index (SAIFI)

Rate of failures that occurred per customer served each time (generally annual). This index is determined by dividing the number of all failures in one year with the number of customer served by the system.

$$SAIFI = \frac{\sum \lambda_k \cdot M_k}{\sum M} \quad (5)$$

Where λ_k is failure rate of line, M_k is load number failure of line, and M is load number of line.

b. System Average Interruption Duration Indeks (SAIDI)

the average value of length of failure for each customer during one year. This index is determined by division number and length of continuous failure to customers over a period of time determined by the number of customers served for a year.

$$SAIDI = \frac{\sum \mu_k \cdot M_k}{\sum M} \quad (6)$$

Where μ_k is downtime rate of line

c. Customer Average Interruption Duration Index (CAIDI)

The index duration disturbance of the average consumer each year, inform the average time for recovery of failure each customer in one year.

$$CAIDI = \frac{SAIDI}{SAIFI} \quad (7)$$

(7)

A. Perfect Switching

TABEL 3. INDEX OF REALIBILITY

Bus Station	Feeder	SAIFI	SAIDI	CAIDI
Pekanbaru	12 Kualu	0,30	1,19	6,63

From TABEL 3.can be seen the results of the analysis and calculation for the reliability value of SAIFI 0.30 times/year, SAIDI 1.19 hour/year, CAIDI 6.63 hours/year. Based on the calculation RIA method for the reliability of the value SAIFI, SAIDI, CAIDI and feeder 12 Kualu still reliable. This is because the value of reliability of SAIFI, SAIDI is smaller than the maximum limits set by the standards of the PLN.




Fig.4.SAIFI, SAIDI, and CAIDI of Realibility in Perfect Switching

B. Imperfect Switching

TABEL 4. INDEX OF REALIBILITY

Bus Station	Feeder	SAIFI	SAIDI	CAIDI
Pekanbaru	Feeder 12 Kualu	0,63	4,19	6,65

From TABLE 4 can be seen the results of the analysis and calculation for the reliability value of 0.63 times/year SAIFI, SAIDI 4.19 hours/year, CAIDI 6.65 hours/year. Based on the calculation RIA method for the reliability of the value SAIFI, SAIDI, CAIDI and feeder 12 Kualu still reliable. This is because the value of reliability of SAIFI, SAIDI is smaller than the value specified by the standards of the PLN.




Fig.3. Stage og Research with RIA Method

There are a few things to know before calculating system reliability index that is by knowing the value of equipment reliability data. These data were obtained from the SPLN 59 in 1985 for equipment reliability data [12]. Index of reliability on radial SUTM SPLN 68-2 in 1986 where for SAIFI was 3.2 times/year and SAIDI of 21 hours/year [14].

III. RESULT AND ANALYSIS OF REALIBILITY

TABEL 2. MTTF AND MTTR OF FEEDER 12 KUALU

Bus Station	Feeder	MTTF (day)	MTTR (hour)
Pekanbaru	12 Kualu	6,1	1,064

The results in TABLE 2 can be seen the average value of the failures that occurred during the operation of the system (MTTF) is 6.1 day. While the value of the average time required to perform the repairs against the occurrence of the failure of a system (MTTR) is 1.064 hours.




Fig.5.SAIFI, SAIDI, and CAIDI of Realibility in Imperfect Switching




Fig. 6.Comparison chart value SAIFI, SAIDI, CAIDI Perfect and Imperfect Switching

In determining the level of reliability by using RIA method, there are two conditions, where the first condition is perfect and the second is imperfect switching. To get the index value of the reliability of SAIFI, SAIDI, CAIDI in perfect switching, component that exists on a network system is assumed to be working perfectly so the index failure on component can be ignored, then the calculated only failure on the line.

Whereas, in the conditions of imperfect switching to get value of SAIFI, SAIDI, CAIDI can be known and by which a piece of equipment on the network distribution is assumed not perfect, the index of failure any equipment the distribution system provide impact on overall reliability system.

From TABLE 3, 4 and Fig. 4. can be seen comparison condition of perfect switching and imperfect switching. For the value of SAIFI, SAIDI, CAIDI larger in conditions of imperfect switching. It is because in the distribution network at feeder 12 Kualu each component is failure give impact on the reliability of the index. Nevertheless the difference for good reliability index condition of Perfect and Imperfect switching for SAIFI, SAIDI, CAIDI and still reliable. Because the value obtained in the calculation method of RIA smaller than standard from the standard PLN. PLN 68-2 in 1986 for SAIFI i.e. 3.2 times/year, and SAIDI 21 hours/year.

IV. CONCLUSIONS

Index of reliability in PT. PLN (Persero) Rayon Panam feeder 12 kualu for SAIFI and SAIDI value still reliable in

condition Perfect Switching as well as the conditions of Imperfect Switching. The value obtained is still smaller than the maximum limit by PLN. As for the value of the Perfect Switching conditions for SAIFI 0.30 times/year, SAIDI 1.19 hours/year and CAIDI 6.63 hours/year. Whereas the conditions of Imperfect Switching SAIFI 0.63 times/year, SAIDI 4.19 hours/year, and CAIDI 6.65 hours/year.

Reliability index value Differences not significant between the Perfect Switching and Imperfect Switching condition. This is because the conditions of Perfect Switching index calculated on the line, while the conditions of Imperfect Switching of index are calculated every distribution equipment that provides the value of the index failure throughly.

References

- [1] Billinton, R.; Billinton, J., "Distribution System Reliability Indices", IEEE Trans, 1989, PWRD-4,(1),pp. 561-568.
- [2] Richard E. Brown, "Electric Power Distribution Reliability", Second Edition,1988:46-48.
- [3] Prabowo Herdianto,2012.Studi Analisis Keandalan Sistem Distribusi PT. Semen Gersik Tribun Menggunakan Metode Reliability Index Assessment (RIA) dan Software ETAP (electrical Transient Analysis Program). Teknologi Sepuluh Nopember Surabaya.Vol.1,No1,ISSN:2301-9271.
- [4] Penagseng Ontoseno,2012.Studi perbaikan keandalan jaringan distribusi primer dan pemasangan gardu induk sisipan kabupaten Enrekang Sulawesi Selatan. Vol. 1, ISSN: 2301-9271
- [5] Li, Fangxing, "DistributedProcessing of Reliability Index Assessment and Reliability-Based Network Reconfiguration in Power Distribution System", IEEE Transaction on Power Systems, Vol.20, No. 1, pp.231, February, 2005.
- [6] Saoda Siti,2008. Evaluasi keandalan sistem distribusi tenaga listrik berdasarkan SAIDI dan SAIFI. Institut Teknologi Nasional.Yogyakarta.
- [7] Suswanto Daman,2010.Sistem Distribusi Tenaga Listrik. Institut Teknologi Sepuluh November.
- [8] Rahmat Gheschik Safiur,2013.Evaluasi indeks keandalan sistem jaringan distribusi 20 kV di Surabaya menggunakan Loop Restoration Scheme. Vol. 2, No. 2, ISSN: 2337-3539 (2301-9271 Print)
- [9] Soeprijanto Adi,Peningkatan Keandalan Sistem Distribusi Tenaga Listrik 20 kV PT. PLN (Persero) APJ Magelang Menggunakan Static Series Voltage Regulator (SSVR)" Surabaya.
- [10] Rendra Prambudhi Setyo,2008. Meningkatkan keandalan sistem distribusi 20 kV dengan penambahan sectinalizer.Institut Teknologi Sepuluh November.Surabaya
- [11] Brown, R.E., "Distribution System Reliability Assessment: Momen Interruptions and Storms", IEEE Transactions on Power Delivery Vol. 12, No. 4, p.1572, October, 1997

-
- [12] Departemen Pertambangan dan Energi, Perusahaan Umum Listrik Negara, Lembaga Masalah Ketenaga Listrikan, SPLN 59 : 1985, Jakarta , 1985, hal.7.
 - [13] Brown, R.E., “*Distribution System Reliability Assessment: Momentary Interruptions and Storms*”, *IEEE Transactions on Power Delivery* Vol. 12, No. 4, p.1572, October, 1997.
 - [14] Departemen Pertambangan dan Energi, Perusahaan Umum Listrik Negara, Lembaga Masalah Ketenaga Listrikan, SPLN 68-2 : 1986, Jakarta , 1985, hal.11.

